

# ThermaData Lite Report

Instrument Name: Walk-in Monitor

## Instrument Details

Instrument Serial	D19070967
Firmware Version	V 1.2.0.0
Earliest Reading	02-28-19 14:56:28
Latest Reading	02-28-19 15:11:46
Start Condition	Falling temperature
Recording Interval	6Sec
High Alarm	38.0°F
Low Alarm	31.0°F

## Log Summary


Total Time Logging	15Min 18Sec
Total Readings	154
Readings in Alarm	154
Max Temperature	56.1°F
Average Temperature	39.4°F
Min Temperature	38.0°F
Total time in Alarm	15Min 18Sec
Total time out of Alarm	0Sec

## Longest 5 Alarms

Index	Start	Duration	Deviation from Alarm
1	02-28-19 14:56:28	15Min 18Sec	18.1°F
2			
3			
4			
5			

## Calibration

This instrument has been calibrated against laboratory standards which are traceable, via International Agreement to all major National Standards, including the NPL and NIST.



## Handwritten Notes

Received by \_\_\_\_\_ Date \_\_\_\_\_

## Instructions

Take to MOD if found outside of the cooler.